## ADDENDUM NO. 2 TO ANS AND SPECIFICATION

## PLANS AND SPECIFICATIONS FOR

EDITH KANAKA'OLE MULTI-PURPOSE STADIUM BUILDING ADDITION & IMPROVEMENTS JOB NO. PR-4166 SOUTH HILO, HAWAI'I COUNTY AND STATE OF HAWAI'I

#### **NOTICE TO BIDDERS**

The items listed below are made a part of the current contract and shall govern the work, taking precedence over the previously issued specifications and drawings governing the particular item of work mentioned.

#### **DRAWINGS**

Addendum No. 2 revisions marked on the plans with a delta 2 symbol, dated 11/26/12.

ITEM NO. 1 - SHEET TS2 REPLACE in its entirety.

ITEM NO. 2 - SHEET A11.7.1 REPLACE in its entirety.

ITEM NO. 3 – SHEET E1.0 REPLACE in its entirety.

ITEM NO. 4 - SHEET E2.5 REPLACE in its entirety.

ITEM NO. 5 - SHEET E3.0 REPLACE in its entirety.

#### REQUEST FOR INFORMATION/REQUEST FOR CLARIFICATION

1. QUESTION: What is the brand of the existing switchboard DP?

**RESPONSE**: Cutler Hammer Type VB Switchgear, Serial Number 5LF775290A, 277/480V, 3ph, 4W, 800A.

2. QUESTION: Should the glu-lams be V-8 type or V-4?

RESPONSE: See Sheet S1.1 - WOOD

Warren H. W. Lee, P.E., Director Department of Public Works County of Hawai'i

Date Issued: November 26, 2012

Please detach and execute the receipt below. Return immediately via facsimile (808) 961-8630 or mail to the Administration Office, Department of Public Works, County of Hawai'i at Aupuni Center, 101 Pauahi Street, Suite 7, Hilo, HI 96720-4224.

Receipt of Addendum No. 2 via website for the EDITH KANAKA'OLE MULTI-PURPOSE STADIUM BUILDING ADDITION & IMPROVEMENTS, Job No. PR-4166, South Hilo, Hawai'i, is hereby acknowledged.

Signed	Title
Firm	Date

### **DRAWING INDEX**

DWG NO	SHT NO	DESCRIPTION	DWG NO	<u>SHT</u> <u>NO</u>	DESCRIPTION	DWG NO	SHT NO	DESCRIPTION
1.	TS1	TITLE TITLE, LOCATION MAP, VICINITY MAP, PROJECT	43.	A7.1.2	CABINET DETAILS ADDITIVE ALTERNATE #2 — STADIUM —	90.	A13.3	DRESSING BLDG — ACCESSIBLE ROUTE FLOOR PLAN
2.	TS2	DIRECTORY, APPROVALS DRAWING INDEX	44.	A8.1.1	CABINET DETAILS  ADDITIVE ALTERNATE #3 — STADIUM —	91. 92.	A13.4 A13.5	ACCESSIBLE DETAILS ACCESSIBLE DETAILS
3.	TS3	CODE INFORMATION, ENERGY CALCULATIONS	45.	A9.1.1	EXISTING FLOOR PLAN ADDITIVE ALTERNATE #4 — STADIUM —	93.	A13.6	ACCESSIBLE DETAILS STRUCTURAL
		CIVII			EXISTING/NEW FLOOR PLAN	94.	S1.0	STRUCTURAL NOTES
4.	C1.0	CIVIL NOTES	46.	A9.2.1	ADDITIVE ALTERNATE #4 — STADIUM — EXISTING/NEW PARTIAL FLOOR PLAN,	95. 96.	S1.1 S1.2	STRUCTURAL NOTES STRUCTURAL DETAILS
5. 6.	C1.1 C1.2	CIVIL DETAILS CIVIL DETAILS			REFLECTED CEILING PLAN, ROOF PLAN, SECTIONS THRU BUILDING, EXTERIOR ELEV,	97. 98.	S1.3 S1.4	STRUCTURAL DETAILS STRUCTURAL DETAILS
7. 8.	C2.0 C2.1	OVERALL SITE PLAN PARTIAL SITE PLAN PARTIAL SITE PLAN	47.	A10.1.1	ADDITIVE ALTERNATE #5 — STADIUM — EXISTING FLOOR PLAN / DEMOLITION	99. 100.	S1.5 S1.6	STRUCTURAL DETAILS STRUCTURAL DETAILS
9. 10.	C2.2 C3.0	PARTIAL SITE PLAN (**) OVERALL GRADING PLAN	48.	A10.1.2	ADDITIVE ALTERNATE #5 — STADIUM — EXISTING PARTIAL FLOOR PLAN / DEMOLITION	101. 102.	S2.0 S2.1	KEY PLAN RESTROOM BUILDING PLAN
11. 12.	C3.1 C3.2	PARTIAL GRADING PLANS PARTIAL GRADING PLANS	49.	A10.2.1	ADDITIVE ALTERNATE #5 - STADIUM - EXISTING/NEW FLOOR PLAN	103.	S2.2	CONCESSION 'A' FOUNDATION & ROOF FRAMING PLAN
			50.	A10.2.2	ADDITIVE ALTERNATE #5 — STADIUM —	104.	S2.3	CONCESSION 'B' FOUNDATION & ROOF FRAMING PLAN
13.	A1.0	ARCHITECTURAL ABBREVIATIONS, GENERAL SYMBOLS	51.	A10.3.1	EXISTING/NEW PARTIAL FLOOR PLAN ADDITIVE ALTERNATE #5 — STADIUM —	105. 106.	S2.4 S2.5	DRESSING BUILDING FOUNDATION PLAN DRESSING BUILDING ROOF FRAMING PLAN
14. 15.	A1.1 A1.2	EXISTING SITE PLAN / DEMOLITION			EXISTING SECTION THRU BUILDING / DEMOLITION, EXISTING NEW SECTION THRU	107.	S3.0	BUILDING SECTIONS
16.	A2.1.1	EXISTING/NEW SITE PLAN STADUM - EXISTING FLOOR PLAN /	52.	A11.1	BUILDING DRESSING BLDG — FLOOR PLAN	100	P1.0	MECHANICAL BLUMBING SOVER SHEET
17.	A2.1.2	DEMOLITION STADIUM — EXISTING PARTIAL FLOOR PLANS	53. 54.	A11.2 A11.3	DRESSING BLDG — EXTERIOR ELEVATIONS DRESSING BLDG — REFLECTED CEILING PLAN	108. 109.	P2.0	PLUMBING COVER SHEET PLUMBING SITE PLAN
18.	A2.2.1	/ DEMOLITION STADIUM — EXISTING/NEW FLOOR PLAN	55. 56.	A11.4 A11.5.1	DRESSING BLDG — ROOF PLAN DRESSING BLDG — SECTIONS THRU BUILDING	110. 111.	P2.1 P2.2	PLUMBING PLAN — EXISTING DEMOLITION PLUMBING PLAN — EXSITING/NEW
19.	A2.2.2	STADIUM — EXISTING PARTIAL FLOOR PLANS / DEMOLITION	57. 58.	A11.5.2 A11.6.1	DRESSING BLDG — SECTIONS THRU BUILDING	112. 113.	P2.3 P2.4	PLUMBING PLAN — DRESSING BUILDING ADD ALT #1 — PLUMBING PLAN — DRESSING
20.	A2.3.1	STADIUM - EXISTING EXTERIOR ELEVATION /	59.	A11.6.2	DRESSING BLDG — WALL SECTIONS DRESSING BLDG — WALL SECTIONS DRESSING BLDG — WALL SECTIONS	114.	P2.5	BUILDING " ADD ALT #2 — EXIST PARTIAL PLUMBING
		DEMOLITION, EXISTING/NEW EXTERIOR ELEVATION	60. 61.	A11.6.3 A11.7.1	DRESSING BLDG — WALL SECTIONS DRESSING BLDG — DETAILS	115.	P3.0	PLAN & DÏAGRAMS — STADIUM RESTROOM BUILDING — SANITARY PIPING
21.	A2.4.1	STADIUM — EXISTING SECTION THRU BUILDING  / DEMOLITION, EXISTING/NEW SECTION THRU	62. 63.	A11.7.2 A11.8.1	DRESSING BLDG — DETAILS DRESSING BLDG — INTERIOR ELEVATIONS	116.	P3.1	DIAGRAM RESTROOM BUILDING — SANITARY PIPING
22.	A3.1.1	BUILDING ADDITIVE ALTERNATE #2 — STADIUM —	64. 65.	A11.8.2 A11.9.1	DRESSING BLDG — INTERIOR ELEVATIONS DRESSING BLDG — DOOR SCHEDULE, TYPES,	117.	M1.0	DIAGRAM MECHANICAL COVER SHEET
23.	A3.1.2	EXISTING FLOOR PLANS / DEMOLITION ADDITIVE ALTERNATE #2 — STADIUM —	66.	A11.9.2	DTLS DRESSING BLDG — WINDOW SCHE., TYPES,	118. 119.	M2.0 M2.1	MECHANICAL SITE PLAN PARTIAL VENTILATION FLOOR PLAN
24.	A3.1.3	EXISTING PARTIAL FLOOR PLANS / DEMOLITION ADDITIVE ALTERNATE #2 — STADIUM —	67.	A11.10	DETAILS DRESSING BLDG — FINISH SCHEDULE, SIGN	120.	M2.2	ADDITIVE ALTERNATE #3 — PARTIAL VENTILATION FLOOR PLAN
25.	A3.2.1	EXISTING PARTIAL FLOOR PLAN / DEMOLITION ADDITIVE ALTERNATE #2 - STADIUM -	68.	A11.11	SCHEDULE, TYPES, DETAILS DRESSING BLDG — CABINET DETAILS	121.	M3.0	MECHANICAL DETAILS
		EXISTING/NEW FLOOR PLAN	69. 70.	A11.12 A11.13.1	FINISH FLOORING LAYOUT PLAN ADDITIVE ALTERNATE #1 — PARTIAL FLOOR	122.	E1.0	ELECTRICAL ELECTRICAL COVER SHEET
26.	A3.2.2	ADDITIVE ALTERNATE #2 — STADIUM — EXISTING/NEW PARTIAL FLOOR PLANS	71.	A11.13.2	PLAN, FINISH SCHEDULE, SIGN SCHEDULE ADDITIVE ALTERNATE #1 — INTERIOR	123.	E2.0	ELECTRICAL SITE PLAN
27.	A3.2.3	ADDITIVE ALTERNATE #2 — STADIUM — EXISTING/NEW PARTIAL FLOOR PLAN	72.	A11.13.3	ELEVATION ADDITIVE ALTERNATE #1 — DRESSING BLDG —	124. 125.	E2.1 E2.2	POWER PLAN — DRESSING ROOM BUILDING LIGHTING PLAN — DRESSING ROOM BUILDING
28.	A3.3.1	ADDITIVE ALTERNATE #2 — STADIUM — EXISTING EXTERIOR ELEVATIONS / DEMOLITION	73.	A12.1	SECTION THRU BUILDING, WALL SECTIONS RESTROOM BLDG — EXISTING FLOOR PLAN /	126. 127.	E2.3 E2.4	ELECTRICAL PLAN — RESTROOM BUILDING ELECTRICAL PLANS — STADIUM CONCESSION
29.	A3.3.2	ADDITIVE ALTERNATE #2 — STADIUM — EXISTING/NEW EXTERIOR ELEVATIONS	74.	A12.2	DEMOLITION RESTROOM BLDG — EXISTING/NEW FLOOR	128. 129.	E2.5 E2.6	ELECTRICAL PLAN — TV VAN AREA ELECTRICAL PLAN — ADD ALT #4
30.	A4.1.1	ADDITIVE ALTERNATE #2 — STADIUM —			PLAN	130. 131.	E3.0 E4.0	ELECTRICAL SINGLE LINE DIAGRAM, SCHEDULES PANEL SCHEDULE & ELECTRICAL DETAILS
31.	A4.1.2	EXISTING/NEW REFLECTED CEILING PLAN ADDITIVE ALTERNATE #2 — STADIUM —	75.	A12.3	RESTROOM BLDG — EXISTING EXTERIOR ELEVATION / DEMOLITION, EXISTING/NEW			LANDSCAPING
70	4404	EXISTING/NEW PARTIAL REFLECTED CEILING PLAN	76.	A12.4.1	EXTERIOR ELEVATIONS RESTROOM BLDG — EXISTING REFLECTED	132. 133.	L1.1 L2.1	EXISTING/NEW PARTIAL SITE PLAN PARTIAL LAYOUT PLAN ENLARGEMENTS/
32.	A4.2.1	ADDITIVE ALTERNATE #2 - STADIUM - EXISTING/NEW ROOF PLAN	77.	A12.4.2	CEILING PLAN / DEMOLITION RESTROOM BLDG — EXISTING/NEW REFLECTED	134.	L2.2	LAYOUT NOTES/LEGEND PARTIAL LAYOUT PLAN ENLARGEMENTS/
33.	A4.2.2	ADDITIVE ALTERNATE #2 — STADIUM — EXISTING/NEW PARTIAL ROOF PLAN	78.	A12.5.1	CEILING PLAN RESTROOM BLDG — EXISTING/NEW ROOF PLAN	135.	L3.1	PLANTING NOTES PARTIAL PLANTING PLAN ENLARGEMENTS
34.	A5.1.1	ADDITIVE ALTERNATE #2 — STADIUM — EXISTING SECTIONS THRU BUILDING /	79.	A12.6.1	RESTROOM BLDG — EXISTING SECTION THRU BUILDING / DEMOLITION	136.	L3.2	PARTIAL PLANTING PLAN ENLARGEMENTS/
35.	A5.1.2	DEMOLITION ADDITIVE ALTERNATE #2 — STADIUM —	80.	A12.6.2	RESTROOM BLDG — EXISTING/NEW SECTION THRU BUILDING	137.	L4.1	PLANTING NOTES DETAIL/ PLANTING LIST
36.	A5.1.3	EXISTING/NEW SECTIONS THRU BUILDING ADDITIVE ALTERNATE #2 — STADIUM —	81.	A12.7.1	RESTROOM BLDG - WALL SECTIONS			
		EXISTING/NEW PARTIAL SECTIONS THRU BLDG	82. 83.	A12.8.1 A12.9.1.	RESTROOM BLDG — DETAILS RESTROOM BLDG — EXISTING INTERIOR			
37.	A5.1.4	ADDITIVE ALTERNATE #2 — STADIUM — EXISTING/NEW PARTIAL SECTIONS THRU BLDG	84.	A12.9.2	ELEVATIONS / DEMOLITION RESTROOM BLDG — EXISTING/NEW INTERIOR			
38.	A5.2.1	ADDITIVE ALTERNATE #2 — STADIUM — WALL SECTIONS	85.	A12.10	ELEVATIONS RESTROOM BLDG — DOOR SCHEDULE, TYPES,			
39.	A5.2.2	ADDITIVE ALTERNATE #2 — STADIUM — WALL SECTIONS	86.	A12.11	DTLS RESTROOM BLDG — FINISH SCHEDULE, SIGN			
40.	A6.1.1	ADDITIVE ALTERNATE #2 — STADIUM — DETAILS	87.	A12.12	SCHEDULE, TYPES, DETAILS FINISH FLOORING LAYOUT PLAN			
41.	A6.1.2	ADDITIVE ALTERNATE #2 — STADIUM — DETAILS, INTERIOR ELEVATIONS	88. 89.	A13.1 A13.2	SITE PLAN — ACCESSIBLE ROUTE STADIUM — RESTROOM — ACCESSIBLE ROUTE			
42.	A7.1.1	ADDITIVE ALTERNATE #2 - STADIUM -			FLOOR PLAN			

FLEMING & Associates, LLC 557 MANONO STREET HILD, HAWAII






		ä	REVIEWED:	: 001
=				
	11/26/12 ADDENDUM #2	11/26/12	$\lor$	
		מוור	MANIA	

EDITH KANAKA'OLE MULTI-PURPOSE STADIUM BUILDING ADDITION & IMPROVEMENTS

COUNTY OF HAWA!!
DEPARTMENT OF PARKS & RECREATION
101 PAUAH STREET, SUITE 6./HLC, HAWAII 96720 PHO

TS2 р Р



- FINAL CONNECTIONS & ROUGH-IN REQUIREMENTS TO EQUIPMENT SHALL BE PER MANUFACTURER'S APPROVED WIRING DIAGRAMS DETAILS AND INSTRUCTIONS IT SHALL BE THE CONTRACTOR RESPONSIBILITY TO PROVIDE MATERIALS AND EQUIPMENT COMPATIBLE WITH EQUIPMENT ACTUALLY
- ALL EMPTY RACEWAY SYSTEMS SHALL HAVE A #12 PULLWIRE OR EQUAL AND SHALL BE IDENTIFIED AT ALL JUNCTION, PULL AND TERMINATION POINTS, USING PERMANENT METALLIC TAGS. TAG SHALL INDICATE INTENDED LISE OF CONDUIT ORIGINATION AND TERMINATION POINTS OF EACH INDIVIDUAL CONDUIT. STUB CONDUIT OUT 6" INTO AN ACCESSIBLE AREA. CAP OPEN ENDS NOT TERMINATED IN A
- FIXTURES INDICATED AS BEING ON EMERGENCY OR NIGHT LIGHT CIRCUITS SHALL BE PROVIDED WITH SELF-CONTAINED BATTERY POWERED INVERTER UNIT FOR DIRECT MOUNTING IN FIXTURE, PROVIDE UNIT WITH FULLY AUTOMATIC TWO RATE CHARGER, NICKEL CADMIUM BATTERY, AC "ON" PILOT LIGHT, AND NORMAL AC POWER AND TO OPERATE FOR MINIMUM 1-1/2 HOURS.
- IT IS THE INTENT OF THESE DRAWINGS AND SPECIFICATIONS TO ESTABLISH A STANDARD OF QUALITY. 29. PANEL DIRECTORIES SHALL BE REMOVABLE. SUBMIT PROPOSED SCHEDULE OF DIRECTORIES TO OWNER
- CONTRACTOR SHALL REVIEW ARCHITECTURAL, STRUCTURAL, MECHANICAL AND OTHER DRAWINGS PRIOR
- CONTRACTOR SHALL VISIT SITE PRIOR TO BID AND VERIFY THAT CONDITIONS ARE AS INDICATED. CONTRACTOR SHALL REPORT DISCREPANCIES TO THE ARCHITECT AND INCLUDE IN HIS BID ALL COSTS REQUIRED TO MAKE HIS WORK MEET EXISTING CONDITIONS.
- PROPOSED SUBSTITUTIONS OF ELECTRICAL EQUIPMENT OR REQUEST FOR "OR EQUAL" OR "APPROVED EQUAL" LISTING SHALL BE SUBMITTED TO ARCHITECT NOT LESS THAN TEN (10) WORKING DAYS PRIOR
- WORK SHALL BE PERFORMED IN A WORKMANLIKE MANNER TO THE SATISFACTION OF THE ARCHITECT.
- 10. WORK, MATERIALS AND EQUIPMENT SHALL CONFORM TO THE LATEST EDITIONS OF LOCAL, STATE AND
- 11. PROVIDE PERMITS AND INSPECTIONS REQUIRED.
- GUARANTEE THE INSTALLATION AGAINST DEFECTS IN MATERIALS AND WORKMANSHIP WHICH MAY OCCUR UNDER NORMAL USAGE FOR A PERIOD OF ONE YEAR AFTER OWNER'S ACCEPTANCE. DEFECTS SHALL BE PROMPTLY REMEDIED WITHOUT COST TO THE OWNER.
- PROVIDE RECORD DRAWINGS TO ARCHITECT. DRAWINGS SHALL INCLUDE ALL ADDENDUM ITEMS, CHANGE ORDERS, ALTERATIONS, REROUTINGS, ETC.
- 14. VERIFY EXACT LOCATION OF EQUIPMENT TO BE FURNISHED BY OTHERS PRIOR TO ROUGH-IN.
- SYSTEMS SHALL BE TESTED FOR PROPER OPERATION. IF TESTS SHOW THAT WORK IS DEFECTIVE, CONTRACTOR SHALL MAKE CORRECTIONS NECESSARY AT NO COST TO OWNER.
- SYSTEM OUTAGES SHALL BE PERMITTED ONLY AT TIMES APPROVED BY OWNER, IN WRITING. WORK SYSIEM OUTAGES SHALL BE PERMITTED UNIX AT TIMES APPROVED BY OWNER, IN MINIMO, MONTH WHICH COLUD RESULT IN AN ACCIDENTAL OUTAGE (BEYOND BRANCH CIRCUITS) SHALL BE PERFORMED WITH THE OWNER'S MAINTENANCE PERSONNEL ADVISED OF SUCH WORK. SERVICE SHALL BE MAINTAINED 37. TO EXISTING AREAS DURING CONSTRUCTION. CONTRACTOR SHALL PROVIDE PORTRABLE CENERATORS, TEMPORARY POWER, CABLES, OUTLETS, ETC., AS REQUIRED TO MAINTAIN CONTINUITY OF SERVICE.

  38. PLACEMENT OF SUCH PORTABLE EQUIPMENT SHALL BE SUBJECT TO OWNER APPROVAL.
- WIRE SHALL BE COPPER, 75°C RATED FOR GENERAL USE, FOR HID FIXTURES AND WIRING WITHIN 3 INCHES OF FLUORESCENT BALLASTS WIRE SHALL BE COPPER, MINIMUM 90°C RATED. SIZES INDICATED ARE FOR INSTALLATION IN A MAXIMUM 30°C AMBIENT. CONDUCTOR AMPACITY SHALL BE DERATED FOR HIGHER AMBIENT INSTALLATIONS.
- SPLICES IN EXTERIOR PULLBOXES AND MANHOLES SHALL BE MADE WATERPROOF USING "SCOTCHCAST" SPLICE KIT OR APPROVED EQUAL. SEAL ENDS OF CONDUITS AND DUCTS WITH "DUCTSEAL" OR
- 19. PRESENT SHOP DRAWING SUBMITTAL DATA AT ONE TIME, BOUND IN THREE-RING BINDERS, INDEXED IN 41. A NEAT AND ORDERLY MANNER. PARTIAL SUBMITTALS WILL NOT BE ACCEPTED. SUBMITTALS SHALL INCLUDE BUT NOT BE LIMITED TO: LIGHTING FIXTURES, TRANSFORMERS, SWITCHGEAR, PANELBOARDS, WIRING DEVICES, SAFETY SWITCHES, LAMPS, CONDUIT, AND CONDUIT FITTINGS.
- CONTRACTOR SHALL BE RESPONSIBLE FOR REPLACING EQUIPMENT WHICH IS DAMAGED DUE TO INCORRECT FIELD WIRING PROVIDED UNDER THIS SECTION OR FACTORY WIRING IN EQUIPMENT PROVIDED
- CONTRACTOR'S FAILURE TO ORDER OR RELEASE ORDER FOR MATERIALS AND/OR EQUIPMENT WILL NOT BE ACCEPTED AS A REASON TO SUBSTITUTE ALTERNATE MATERIALS OR EQUIPMENT.
- SYSTEMS SHALL BE COMPLETE, OPERABLE AND READY FOR CONTINUOUS OPERATION. LIGHTS, SWITCHES, RECEPTACLES, MOTORS, ETC., SHALL BE CONNECTED AND OPERABLE.
- WIRING DEVICES SHALL BE SPECIFICATION GRADE AND RATED AT 20 AMPERES. THE DEVICE PLATES SHALL BE LEXAN OR NYLON (IN KITCHENS WITH STAINLESS STEEL COUNTERS DEVICE PLATES SHALL BE STAINLESS STEEL). THE COLOR OF THE DEVICES AND COVER PLATES SHALL BE AS DIRECTED BY

- 24. PROVIDE SEPARATE NEUTRAL CONDUCTOR FOR EACH GROUND FAULT CIRCUIT.
- VERIFY EXACT LOCATIONS OF EXISTING AND NEW UNDERGROUND UTILITIES. PIPING AND RACEWAY SYSTEMS PRIOR TO TRENCHING. PROVIDE NECESSARY TRENCHING, BACKFILL, EXCAVATION, SUPPORTS, SERVICE FEEDERS (CONDUIT AND/OR WIRE), PULLBOXES, TRANSFORMER PADS, SAWCUTTING AND PATCHING, CONCRETE/PAVING, ETC., REQUIRED, BACKFILL TRENCHES TO 90% COMPACTION AND PATCH
- 26. BOXES SHALL BE MINIMUM 4" SQUARE WITH REQUIRED EXTENSIONS & PLASTER OR TILE RINGS.
- 27. SWITCHBOARDS, DISTRIBUTION BOARDS, PANELBOARDS, DISCONNECT SWITCHES, ETC. SHALL BE MANUFACTURED BY GENERAL ELECTRIC, SIEMENS, SQUARE 'D' OR CUTLER-HAMMER. BOLT FREE STANDING EQUIPMENT TO 4" HIGH CONCRETE HOUSEKEEPING PADS.
- PROVIDE ENGRAVED NAMEPLATES ON SWITCHBOARDS, PANELBOARDS, DISCONNECT SWITCHES, MOTOR CONTROL CENTERS, TRANSFORMERS, ETC., INDICATING EQUIPMENT DESIGNATION (OR DESIGNATION OF
- FOR APPROVAL ROOM NAMES AND NUMBERS SHALL BE AS DIRECTED BY OWNER. DIRECTORIES SHALL BE TYPED AND INSTALLED UNDER CLEAR PLASTIC COVERS.
- DISCONNECT SWITCHES SHALL BE HEAVY DUTY TYPE. INSTALL DISCONNECT SWITCH ON TWO 24" LONG UNISTRUT CHANNELS DRILLED AND BOLTED TO HVAC UNIT FRAME WHERE POSSIBLE (COORDINATE LOCATION W/ HVAC MANUFACTURER TO AVOID WARRANTY INFRACTIONS). SILICONE SEAL ALL HOLES IN
- 31. CIRCUIT BREAKERS SHALL BE BOLT-ON TYPE AND FUSES SHALL BE BUSSMANN.
- PROVIDE 4" HIGH CONCRETE EQUIPMENT PADS BENEATH SWITCHBOARDS, MOTOR CONTROL CENTERS,
- IMMEDIATELY AFTER AWARD OF CONTRACT, CONTRACTOR SHALL VERIFY AVAILABLE PHYSICAL SPACE AND AMPACITY OF EXISTING PANELBOARDS, SWITCHBOARDS, DISTRIBUTION BOARDS, MOTOR CONTROL
  CENTERS, ETC., AND PROVIDE WRITTEN DOCUMENTATION OF FINDINGS TO THE ENGINEER.
  DOCUMENTATION SHALL INCLUDE A MINIMUM 24 HOUR RECORDING AMPERE READING ON ALL EXISTING SWITCHGEAR BEING UTILIZED FOR THIS PROJECT
- ALL WIRING SHALL BE INSTALLED IN LISTED METALLIC RACEWAYS. RACEWAYS IN SLAB-ON-GRADE OR BELOW GRADE SHALL BE SCHEDULE 40 PVC. TRANSITIONS FROM BELOW TO ABOVE GRADE SHALL BE WITH RIGID STEEL ELBOWS WITH P.V.C. JACKET OR APPROVED EQUAL PROTECTION. EMT FITTINGS SHALL STEEL. CONNECTORS SHALL BE INSULATED THROAT TYPE. TYPE MC CABLE MAY BE USED FOR BRANCH CIRCUITS #8 AWG AND SMALLER.
- 35. NON-METALLIC AND FLEXIBLE METAL CONDUITS SHALL HAVE A CODE SIZED COPPER GROUNDING CONDUCTOR. INCREASE CONDUIT SIZE AS REQUIRED.
- FINAL CONNECTIONS TO MOTORS, TRANSFORMERS AND OTHER VIBRATING EQUIPMENT SHALL BE WITH SEAL-TITE FLEX (3'-0" MAXIMUM LENGTH) AND APPROVED FITTINGS. DO NOT SECURE CONDUITS. DISCONNECTS OR DEVICES TO DIJCTWORK OR MECHANICAL FOUIPMENT
- ALL ELECTRICAL SYSTEMS COMPONENTS SHALL BE LISTED OR LABELED BY U.L. OR OTHER RECOGNIZED TESTING FACILITY.
- WIRE TERMINATION PROVISIONS FOR PANELBOARDS, CIRCUIT BREAKERS, SAFETY SWITCHES, AND ALL OTHER ELECTRICAL APPARATUS SHALL BE LISTED AS SUITABLE FOR 75°C.
- RECEPTACLES INSTALLED OUTSIDE, ON THE BUILDING EXTERIOR OR ROOF, IN KITCHENS OR WITHIN 6 FEET HORIZONTALLY FROM A SINK OR DRINKING FOUNTAIN UNLESS LOCATED BELOW A COUNTER OR OTHERWISE PROTECTED SHALL BE GFCI TYPE OR PROTECTED BY GFI CIRCUIT BREAKER.
- WHEN COMPLETE THE ELECTRICAL CONTRACTOR SHALL MEASURE THE STEADY STATE LOAD CURRENTS AT EACH PANEL BOARD FEEDER. SHOULD THE DIFFERENCE AT ANY PANEL BOARD BETWEEN PHASES EXCEED 20%. THE ELECTRICAL CONTRACTOR SHALL REARRANGE CURRENTS IN THE PANEL TO BALANCE
- ALL EQUIPMENT SUCH AS SWITCHBOARDS, DISTRIBUTION BOARDS, DISCONNECT SWITCHES, AND PANELBOARDS SHALL BE BY THE SAME MANUFACTURER. ALL FUSES PROVIDED SHALL BE OF THE SAME
- 42. COORDINATE THE LOCATION OF LIGHTING FIXTURES WITH THE ARCHITECTURAL REFLECTED CEILING PLAN. UNLESS OTHERWISE VERIFIED IN WRITING THE REFLECTED CEILING PLAN LOCATIONS SHALL GOVERN.
- COORDINATE THE LOCATION OF ALL WALL MOUNTED EQUIPMENT WITH THE ARCHITECTURAL INTERIOR AND EXTERIOR ELEVATIONS. UNLESS OTHERWISE VERIFIED IN WRITING THE ARCHITECTURAL DRAWINGS SHALL GOVERN.
- 44. ALL WORK SPECIFIED HEREIN SHALL CONFORM TO THE APPLICABLE REQUIREMENTS OF THE AMERICANS WITH DISABILITIES ACT AND ARCHITECTURAL BARRIERS ACT ACCESSIBILITY GUIDELINES - 2004.

				F	IXTURE S	SCHEDULE	
FIX TYF		MANUFACTURER CATALOG NUMBER	VOLT AMPS	MOUNTING	LAMP TYPE	REMARKS	VOLT
Α	LITHONIA	STL48LMVOLT50WLP835NX (EL14L)	50	SURFACE	LED	SURFACE MOUNTED VOLUMETRIC FLUORESCENT (EL OPTION FOR FIXTURES INDICATED AS EMERGENCY)	277/ 120
В	LITHONIA	FEM4LED5L35IMAFLMVOLT	50	SURFACE, UNLESS OTHERWISE NOTED	LED	4' FULLY ENCLOSED LED	277/ 120
С	COOPER	A04SIA2LED35KUNVWRC3	50	WALL ABOVE MIRROR	LED	4' WALL MOUNTED ETCHED DIFFUSER VANITY LIGHT	277/ 120
Ď	COOPER	E1W-WL-2-L35-1C-UNV-SU-WA	50	WALL @ +96"	LED	4' WALL MOUNTED INDIRECT/DIRECT LED	277/ 120
Е	LITHONIA	FEM4LED5L35IMAFLMVOLT	50	SURFACE, UNLESS OTHERWISE NOTED	LED	8' FULLY ENCLOSED LED	277/ 120
F	LITHONIA	OLVTWM	35	WALL @ +96"	LED	WALL MOUNTED VAPOR TIGHT LED	277/ 120
G	LITHONIA	L7XLEDT24GSKT	10	RECESSED	LED	6" LED DOWNLIGHT (EL OPTION FOR FIXTURES INDICATED AS EMERGENCY)	277/ 120
Н	LITHONIA	ZL2L482300LMV0LTLP835	35	SURFACE	LED	4' FLUORESCENT STRIP FIXTURE WITH WIRE GUARD	277/ 120
<u> </u>	_	-	-	-	-	-	-

#### **ELECTRICAL SYMBOLS** INDICATES MOUNTING HEIGHTS ARE TO CENTERLINE MAIN SWITCHBOARD, MOTOR CONTROL CENTER OR OF DEVICE ABOVE FINISH FLOOR OR FINISH GRADE DISTRIBUTION BOARD INDICATES ABOVE FINISHED FLOOR CONCRETE PULLBOX WITH HEAVY DUTY STEEL TRAFFIC COVER INDICATES CONDUIT WITH PULL-LINE ONLY TRANSFORMER INDICATES GROUND FAULT CIRCUIT INTERRUPTER CIRCUITS PROTECTED WITH GFCI SHALL BE PROVIDED HOMERUN CONDUIT - STROKES INDICATE QUANTITY OF WITH DEDICATED NEUTRALS INDICATES GROUND FAULT PROTECTION CONDUIT AND/OR WIRE CONCEALED IN WALL OR ABOVE CEILING EXCEPT IN EXPOSED STRUCTURE AREAS GRND INDICATES GROUND ---- CONDUIT AND/OR WIRE BELOW FLOOR OR GRADE HELCO INDICATES LOCAL UTILITY CIRCUITING - STROKE WITH DOT INDICATES ISOLATED INDICATES PANEL GROUND CONDUCTOR INDICATES WEATHER-PROOF (NEMA 3R) -- 1/2"-2 #12 & 1 #12 GRND THWN UNLESS NOTED LETTER INDICATES LIGHT FIXTURE TYPE AS \_\_\_\_\_\_ 1/2"-3 #12 & 1 #12 GRND THWN UNLESS NOTED INDICATED ON FIXTURE SCHEDULE 1/2"-4 #12 & 1 #12 GRND THWN UNLESS NOTED FLUORESCENT FIXTURE CIRCUIT BREAKER FLUORESCENT FIXTURE DOWNLIGHT FIXTURE GROUNDING FLECTRODE DOWNLIGHT FIXTURE ON EMERGENCY CIRCUIT OR INTEGRAL BATTERY BACK-UP SINGLE METER WITH CT WALL MOUNTED FIXTURE DIVISION 23 EQUIPMENT - SEE HVAC AND PLUMBING DRAWINGS EXIT LIGHT WITH DIRECTIONAL ARROWS AS INDICATED SINGLE POLE SWITCH @ +48" UNLESS NOTED GROUND BUS & GROUND ELECTRODES 3-WAY POLE SWITCH @ +48" UNLESS NOTED JUNCTION BOX THERMAL OVERLOAD SWITCH NON-FUSED DISCONNECT SWITCH - 30A, 3P, UNLESS DUPLEX RECEPTACLE @ +18" UNLESS NOTED GFCI RECEPTACLE @ +18" UNLESS NOTED 따 COMPANY SWITCH DOUBLE DUPLEX RECEPTACLE @ +18" UNLESS NOTED TC TIMECLOCK

RECEPTACLE INSTALLED ABOVE COUNTER


HAWAII COUNTY CODE- CHAPTER 5 - BUILDING 2006 IECC & ORDINANCES 09-48 & 10-68 BUILDING ENERGY FEFICIENCY STANDARDS

SURFACE MOUNTED PANELBOARD

FLUSH MOUNTED PANELBOARD


PHOTOCELL (INSTALL ON ROOF FACING NORTH)

I CERTIFY THAT THE DESIGN IS IN CONFORMANCE WITH THE BUILDING ENERGY EFFICIENCY STANDARDS PERTAINING TO SECTION 506 ELECTRICAL POWER AND LIGHTING SYSTEMS SECTION 506 ELECTRICAL POWER AND LIGHTING SYSTEMS









STADIUM


**IMPROVEMENT** TI-PURPOSE

∞ಶ

SOL EP/

I KANAKA'OLE N IING ADDITION { DITH KAN 

ш





1. SERVICE VOLTAGE: 120/208V, 3PH., 4W

2. TYPE OF SERVICE: BELOW GROUND

3. ESTIMATED CONNECTED KVA: 317.0 ESTIMATED DEMAND KVA: 221.9

4. ESTIMATED AVERAGE MEASURED TOTAL DEMAND KVA: 221.9

5. DESIGN SERVICE CAPACITY 1200 AMPERES SERVICE CONDUCTORS: (2) SETS OF #250KCMIL AWG COPPER

6. METERING: RATE SCH J, HELCO STD. B-5 (13 JAW, 200A METER SOCKET)

7. BILLING ADDRESS: COUNTY OF HAWAI'I
DEPARTMENT OF PARKS & RECREATION
101 PAUAHI STREET; SUITE 6
HILO, HAWAII 96720

### 120/208V, 3ø, 4W 1200A, 120/208V, 3ø, 4W **③** ) 200A ( W **© (** 0

SINGLE LINE DIAGRAM - NEW (ADD. ALT. #3)

(E) SWBD. 'DP'

65KAIC

600A, 277/480V, 3ø, 4W

#6 PER NEC 250.30

PANEL

DR1

#### **NOTES**

1

- PROVIDE 20 LF OF #3/0 CU PER NEC 250.52(A)(3).
- 2 PROVIDE #3/0 CU PER NEC 250.52(A)(5).
- 3
- 4
- (5) PROVIDE RACEWAYS, TRENCHING, BACKFILLING, BOXES, ETC. PER

  - PROVIDE STAGECRAFT #600-400-C OR EQUIVALENT 400A COMPANY
  - PROVIDE STAGECRAFT #600-200-C OR EQUIVALENT 200A COMPANY SWITCH WITH (5) CAM-LOCK RECEPTACLES.

		FEEDER S	SCHEDULE
	FDR. NO.	DESCRIPTION	CONDUIT AND WIRE SIZE (75° C CU 600V) (105°C 15 & 5KV)
	<b>₽</b> 3>	75KVA XFMR 480V PRIMARY FEEDER (110A MOCP)	1 1/2" - 3 #1 & 1 #6 GRND
	\$3	75KVA XFMR 208V SECONDARY FEEDER (225A MOCP)	2 1/2"-4 #4/0 & 1 #2 GRND
	\$7	300KVA XFMR 208V SECONDARY FEEDER CONCRETE ENCASED (1200A MOCP)	(3) 4" EA W/ 4 #400KCM & 1 #3/0 GRND
,	42>	200A, DISTRIBUTION FEEDER	2"-4 #3/0 & 1 #6 GRND
	46>	250A, DISTRIBUTION FEEDER	3"-4 #250KCMIL & 1 #4 GRND
•	NOTES:		

SOME FEEDERS MAY NOT BE USED ON THIS PROJECT.
VOLTAGE DROP MAY REQUIRE THE USE OF A LARGER AMPACITY FEEDER.

# LOAD CALCULATIONS -

SWBD. 'DP'		
EXISTING LOAD	=	220 KVA
+ 25% PER NEC 220.87	=	55 KVA
PNL 'DR1'	=	28.9 KVA
PNL '2A1' (ADD ALT #2)	=	8.6 KVA
TOTAL	=	312.5 KVA
/480V, 3ø	=	376 A

	LOAD CALCULAT	TIONS -	ADD	ALT	#3
<b>S</b>	SWBD. 'MSA'			70.01	0.74
	COMPANY SWITCH 'LTG 1' COMPANY SWITCH 'LTG 2' COMPANY SWITCH 'PWR 1'	= =		72.0 k 72.0 k 57.6 k	(VA
	COMPANY SWITCH PWR 1 COMPANY SWITCH 'PWR 2' COMPANY SWITCH 'PWR 3'	= = =		57.6 k 57.6 k	(VA
	TOTAL /208V, 3ø	= =		316.8 k	

## BASE BID/ADD ALT #2

/480V, 3ø	=	376
TOTAL	_	312.5 KV
PNL '2A1' (ADD ALT #2)	=	8.6 KV
PNL 'DR1'	=	28.9 KV
+ 25% PER NEC 220.87	=	55 KV
EXISTING LOAD	=	220 KV
SWBD. 'DP'		000 1

MULTI-PURPOSE STADIUM I & IMPROVEMENTS AKA'OLE N COUNTY DEPARTME

FLEMING & Associates, LLC 557 MANONO STREET HILO, HAWAII

E3.0	BUILDING A
OF SHEETS	JOB NO.: PR-4166
MBER 14, 2012	PLAN SHEET DESCRIPTION: ELECTRI

SINGLE LINE DIAGRAM - EXISTING/BASE BID/ADD. ALT. #2

EXIST. PANEL TO EXISTING TO EXISTING TO EXISTING LOAD

HELCO PAD MTD. XFMR

4A EXISTING 15KVA 480V-208/120V 3ø, 4W

NEW (1) 3/4"-3 #8

2A1

3

(E) HELCO PAD MTD. XFMR

500KVA, 277/480V, 3ø, 4W

SECONDARY

THIS WORK PART OF ADD. ALTERNATE #2.

METERING PROVISIONS PER HELCO REQUIREMENTS.

NEW PAD MOUNTED TRANSFORMER BY HELCO. PROVIDE NEW 208V, 30, 4W SERVICE AS INDICATED. PROVIDE CONCRETE PAD PER HELCO REQUIREMENTS.

PROVIDE 4" HIGH CONCRETE PAD AROUND EQUIPMENT. REFER TO DETAIL 1 SHEET E4.0.

DRY-TYPE TRANSFORMER, 480V, 30, E3, DELTA TO 208/120V, 30, 4W WYE, 115°C RISE, 220°C CLASS INSULATION AND KVA SIZE AS

PROVIDE 4" HIGH CONCRETE PAD AROUND EQUIPMENT. 9

SWITCH WITH (5) CAM-LOCK RECEPTACLES.